

ADDENDUM NO. 3

COUNTY OF KAUAI
DEPARTMENT OF WATER

PLANS, BID PROPOSAL, SPECIFICATIONS
CONTRACT AND BOND
FOR

JOB NO. 16-04, WP2020 #WKK-03
MCC, Chlorination Facilities-Kilauea Wells No.1 and No.2
Kilauea Water System
Kilauea, Kaua'i, Hawai'i

NOTICE TO PROSPECTIVE PROPOSERS

This addendum is hereby made a part of the PLANS, BID PROPOSAL, SPECIFICATIONS, CONTRACT AND BOND for the subject project and it shall amend the said contract documents in the following respects:

Item 1

Changes to Special Provisions regarding Section SP-7.2 Pumping Units are as follows:

Section 7.2.05.C.1


Discharge Column Pipe: The new column pipe shall be Schedule 40 galvanized steel pipe conforming to ASTM A53, Grade B, size and thickness as specified, coated with zinc inside and outside by the hot-dip process. Each section of column shall have straight threads with ends accurately machined to form a butt joint to insure accurately assembled column length and perfect alignment. The pipe shall be furnished in interchangeable sections of not more than ten (10) feet in length. The top end (attached to the discharge head bottom) and the bottom (attached to the top of the pump bowl assembly) of the discharge column pipe shall not exceed five (5) feet in length each.

Section 7.2.11.E

NSF/ANSI 61 **COMPLIANCE**: The Contractor shall **provide written verification that the pump, motor, and all other materials are compliant with** the requirements of NSF/ANSI Standard 61.

End of Addendum No. 3

If there are any questions, please contact Mr. Dustin Moises by email at dmoises@kauaiwater.org.



Marites Yano.
Designated Chief Procurement Officer
May 27, 2020

ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM NO. 3

Receipt Acknowledged:

Organization

Received by

Date

Title

(Please sign and return this acknowledgement.)

