

ADDENDUM NO. 1

COUNTY OF KAUA'I
DEPARTMENT OF WATER

PLANS, BID PROPOSAL, SPECIFICATIONS
CONTRACT AND BOND
FOR

JOB NO. 20-01
Kōloa Well D Pump Replacement
Kaua'i, Hawai'i

NOTICE TO PROSPECTIVE PROPOSERS

This addendum is hereby made a part of the PLANS, BID PROPOSAL, SPECIFICATIONS, CONTRACT AND BOND for the subject project and it shall amend the said contract documents in the following respects:

Item 1

Pre-Bid Meeting minutes (none).

Item 2

Change in Scope of Work (Item 5.0) regarding requirements for C37d license. DOW will perform the chlorination and testing. Changes are on following page.

End of Addendum No. 1

If there are any questions, please contact Val Reyna by email at vreyna@kauaiwater.org.

Valentino P. Reyna

Valentino P. Reyna (Jan 7, 2020)

Chief Procurement Officer
January 7, 2020

ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM NO. 1

Receipt Acknowledged:

Organization

Received by

Date

Title

(Please sign and return this acknowledgement.)

ADDENDUM NO. 1

Item 2

Scope of Work

5.0 Upon delivery of the replacement parts and appurtenances, the Contractor shall immediately proceed with assembling and installing the pump/motor assembly along with all re-used and rehabilitated parts. The Contractor shall install the new pump assembly and set the pump impellers as recommended by the pump manufacturer. The Department will reconnect the motor cables. The Contractor shall perform an operational test of the new pump assembly and will perform any needed adjustments to ensure correct operation of the new pump assembly. ~~The Contractor shall chlorinate and flush the well, pump and piping as needed for disinfection.~~ **The Contractor shall coordinate with the Department to assist with chlorination and flushing of the well, pump and piping as needed for disinfection. The Contractor will not be performing the chlorination and thus does not need the C37d license.**

