

ADDENDUM NO. 1

COUNTY OF KAUA'I
DEPARTMENT OF WATER

PLANS, PROPOSAL, SPECIFICATIONS
CONTRACT AND BOND
FOR

JOB NO. 26-02
KŌLOA WELL B PUMP REPLACEMENT
KAUA'I, HAWAI'I

NOTICE TO PROSPECTIVE PROPOSERS

This addendum is hereby made a part of the PLANS, PROPOSAL, SPECIFICATIONS, CONTRACT AND BOND for the subject project and it shall amend the said contract documents in the following respects:

Item 1

SCOPE OF WORK (2.1) CORRECTION: Scope of work should be a 4-pole, not 2-pole. *"The work entails removal of the existing pump/motor and installation of a 10-inch, 4-pole, 75 HP submersible motor that powers a 560 gpm @ 410 TDH pump assembly"*

Item 2

PROCUREMENT SCHEDULE UPDATE: REVISED Bid Opening date is **Wednesday, March 18, 2026 at 2:00pm HST.**

End of Addendum No. 1

Please submit questions for this solicitation at www.publicpurchase.com.



Joseph "Joe" E. Tait
Manager and Chief Engineer
Chief Procurement Officer
March 10, 2026

ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM NO. 1

Receipt Acknowledged:

Organization

Received by

Date

Title

(ADDENDUMS MUST BE ACKNOWLEDGED AND INCLUDED WITH OFFER)